

# SHUTTER FIRE DAMPER

## Certification of Compliance

---



### Construction

Galvanised Steel Frame and Blades

Quick release fusible link for easy testing

High torque stainless constant force spring

Intumescent liner fitted between damper and installation frame

Fusible Link ratings from 72deg C to 227 deg C

### Fire Rating Certification

Chilton Test 01083 to BS476 Pt 20

2 Hour Fire Rated to BS476 pt 20

Optional Stainless Blades to LPC test No T.E.82125

Conforms to recommendation D.W.144

